

RESOLUTION NO. 507

A RESOLUTION AUTHORIZING ACCEPTANCE OF MONTGOMERY ELEVATOR
PROPOSAL FOR ELEVATOR INSTALLATION


WHEREAS, the city staff has prepared a report on the above captioned subject which is attached hereto as Exhibit "A"; and

WHEREAS, the City Council has duly considered the subject and the recommendation(s) contained in the staff report; and


WHEREAS, interested parties, if any, have had an opportunity to be heard on the subject.

NOW, THEREFORE, BE IT RESOLVED that the City Council of the City of Wilsonville does hereby adopt the staff report attached hereto as Exhibit "A", with the recommendation(s) contained therein and further instructs that action appropriate to the recommendation(s) be taken.

ADOPTED by the City Council of the City of Wilsonville at a regular meeting thereof this 5th day of August, 1985, and filed with the Wilsonville City Recorder this same date.


A. G. MEYER, Mayor

ATTEST:


DEANNA J. THOM, City Recorder

CITY OF WILSONVILLE

MEMO

August 5, 1985

DATE

TO: Mayor and City Council
FROM: Daniel O. Potter, City Administrator
SUBJECT: Elevator - Quotation for Supplying

At the Council meeting of July 1, 1985, I reported we had advertised for a bid on an elevator, and no bids had been received. I requested, and you authorized me, to proceed to negotiate a price on the installation of an elevator.

I specifically contacted all the elevator suppliers listed in the telephone book yellow pages and requested that they respond with proposals by 2:00 p.m., July 30, 1985.

We received four proposals from three elevator firms. These are:

Silco Construction Company	
Bidding Otis LRV-2011	
Plunger Electric Passenger Elevator	\$41,134.00
U. S. Elevator	
Hydraulic Elevator	\$40,000.00
Montgomery Elevator Co.	
Model SPM-H2000 Hydraulic Passenger Elevator	\$31,818.00
Model HH-11-2000 Holeless Hydraulic Elevator	
deduct	-1,892.00
	<hr/>
HH-11-2000 Holeless Elevator Net	\$29,926.00
Add Stainless Steel for car doors and	
hoistway entrance and frame in lieu of	
baked enamel finish	+ 797.00
	<hr/>
	\$30,723.00


Installation approximately 10 weeks.

Mayor and City Council
August 5, 1985
Page 2

Recommendation: Accept Montgomery Elevator Company proposal for Model HH-11-2000 Holeless Hydraulic Elevator with stainless steel trim at a cost of \$30,723.00.

(Note: This recommendation eliminates the need to dig a hole 19 feet deep under the lower elevator shaft. It also eliminates a future possible electrolosis problem with the elevator shaft.)

Respectfully submitted,



Daniel O. Potter

DOP/fr